



Compliance Statement

Screened 1200 MHz Enhanced ISO/IEC, EN & ANSI/TIA Communication Cable

Draka – a brand of the Prysmian Group
UC1500 SS22 Cat.7A S/FTP 4P LSHF-FR
1200 MHz Individual Foil and Overall Braid Screened
100 Ω , 4 Twisted Pairs, 22 AWG, Fire Retardant, LSFRHF, Copper Cable

Draka Comteq Germany GmbH & CO. KG.
Piccoloministrasse 2
51063 Köln, Germany

Compliance Statement No. 110499N

This Screened Enhanced ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, IEC Cable Standard 61156-7, incl. amendment 1, the category 6A requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and the requirements of EN 50288-9-1:2012. Fire retardancy is verified according to IEC 60332-3-24 (Cat. C), IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 10. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 10th March 2016

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 10th March 2016

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien
Coordinating Manager